



Certificate of Compliance

This certificate is issued for the following:

**Firefighting Nozzle for Use with Hose, Monitor Assemblies
and other Firefighting Equipment**

Model 4450 Aquastream

| Style | Construction Material | Inlet Nominal Size, in. (mm) | Rated Operating Pressure, psi (bar) | Rated Flow Capacity (settings), GPM (Lpm) |
|-----------------|-----------------------|------------------------------|-------------------------------------|---|
| 4450 Aquastream | Brass | 2.5 (65) | 100 (7) | 300/400/500/530/700 (1140, 1500, 1900, 2000,2650) |

Prepared for:

Akron Brass Co
343 Venture Blvd,
Wooster, OH 44691
United States

Manufactured by:

Akron Brass Co
343 Venture Blvd,
Wooster, OH 44691
United States

FM Approvals Class: 5511

Approval Identification: PR449648

Date Approved: March 28, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group